



Safety Certificate

QLIGHT CO., LTD.

185-25, Mukbang-ro, Sangdong-myeon, Gimhae-si, Gyeongsangnam-do, Republic of Korea

The following product produced by the above company has been authorized for the use of the Mark  as the product has satisfied the safety and health standards stipulated in the article 84 of Industrial Safety and Health Law.

PRODUCT

Flame-Proof LED Light

TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL

QLEX-SLM-650-EMG

CERTIFICATION No.

20-AV2B0-0762X

Ex d IIC T6

CAPACITY · GRADE

-20 °C ≤ Tamb ≤ +60 °C

max. 33 W, AC110 V, 0.49 A or AC230 V, 0.24 A

SAFETY CERTIFICATION STANDARDS


Notification No. 2020-33 of the Ministry of Employment and Labor

CERTIFICATION CONDITION

- It is only for the product manufactured in 185-25, Mukbang-ro, Sangdong-myeon, Gimhae-si, Gyeongsangnam-do, Republic of Korea.
- To prevent static accumulation, clean with a damp cloth.
- A routine overpressure test of 810 kPa shall be carried out on all containers and relevant information shall be provided to the user.

DATE : Feb. 17. 2021

Dec. 24. 2020 (Original issue)

Signature 

President of Korea Occupational Safety and Health Agency